

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010063A-R4  
DATE: 11/17/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: American  
CODE: 1582-1  
REVISION DATE: 07/19/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Skylights</b> <b>1218 Corporate Drive East</b> <b>Arlington, TX 76006</b>	<b>Series "CMD-100" Aluminum</b> <b>Polycarbonate Double Domed Skylight</b>  Configuration: O  Inner Dome: 1/8" Thick Polycarbonate  Outer Dome: 1/8" Thick Polycarbonate  Frame: W-1359mm(53.5") H-2578mm(101.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S. 2/A440-05</b> <b>ASTM E1886-02/E1996-02</b> <b>TAS 201/202/203-94</b>	<b>SKP-HC100 1359 x 2578 (54 x 102)</b> <b>Design Pressure: +100/-100 psf</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 81599.01-801-18/81599.02-801-18/81599.03-801-44  
Expiration Date: **September 30, 2019**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122